

## Declaration of conformity

No.1266

Manufacturer	KLIMAOPREMA d.d. Gradna 78A, 10430 Samobor, Croatia
Person authorized to compile technical documentation	Siniša Murtezanović, <i>mag.eng.mech.</i> Chief technical officer
Product description	General product name: <b>plenum box</b> Product type: <b>plenum box for ceiling diffusers</b> Product model: <b>PBQ, PBR, PBS, PBV, PBI</b> Product use: <b>air distribution element in ventilation systems</b>

We declare under our own responsibility that described products meets the characteristics and properties and is in accordance with the data described in the technical documentation. Technical documentation for the listed product is available on our website: [www.klimaoprema.com](http://www.klimaoprema.com).

We declare under our own responsibility that the described product meets the requirements of the following standards:

EN 13182:2002	Ventilation for buildings -- Instrumentation requirements for air velocity measurements in ventilated spaces
EN 14277:2006	Ventilation for buildings. Air terminal devices. Method for airflow measurement by calibrated sensors in or close to ATD/plenum boxes
EN 15727:2010	Ventilation for buildings – Duct and ductwork components, leakage classification and testing

### Reaction to fire, resistance to fire:

Product is made of galvanized steel sheet and it is considered to be reaction to fire Class A1, in accordance with Commission Decision 1996/603/EC and Commission Decision 2000/605/EC.

### Emissions of dangerous substances:

Product does not contain harmful substances to human and environmental.

Technical documentation reference number: TM 1266.

*EU Declaration of conformity according to the valid EU Directives is not allowed because there are no harmonised standards for the product.*

Signed for the manufacturer on his behalf:

Sergio Galošić, CEO

**2 klimaoprema d.d.**  
Za projektiranje, proizvodnju, postavljanje,  
popravak i održavanje opreme za klimatizaciju  
10430 SAMOBOR, GRADNA 78/A

Samobor, 04.10.2022.